

低压配电盘結線圖(2)

[illegible]

低圧非常保安電灯盤 1φ3W210-105V 320W150kVA			合計243.58kVA (補正負荷 136.7kVA)			
	MCB3P 100/ 75	L-E-05	L-1-1 (E)	13.84	EM-FPT 60"	(E63) or (G70)
	火災信号+停電にてOFF					
	MCB3P 50/ 50	L-G-01	L-B1-1 (G)	9.38	EM-FP 60"-2C	(E63) or (G70)
	MCB3P 50/ 40	L-G-02	L-B1-2 (G)	7.70	EM-CET 22"	(E51) or (G42)
	MCB3P 100/ 75	L-G-03	L-B1-3 (G)	12.05	EM-CET 60"	(E63) or (G70)
	MCB3P 50/ 50	L-G-04	L-B1-4 (G)	8.21	EM-CET 60"	(E63) or (G70)
	MCB3P 50/ 40	L-G-06	L-1-2 (G)	7.43	EM-CET 22"	(E51) or (G42)
	MCB3P 50/ 50	L-G-07	L-1-3 (G)	8.05	EM-CET 38"	(E51) or (G54)
	MCB3P 50/ 40	L-G-08	L-1-4 (G)	7.58	EM-CET 38"	(E51) or (G54)
	MCB3P 100/ 60	L-G-09	L-1-5 (G)	10.67	EM-CET 60"	(E63) or (G70)
	MCB3P 50/ 40	L-G-10	L-1-6 (G)	7.08	EM-CET 38"	(E51) or (G54)
	MCB3P 100/ 60	L-G-11	L-1-7 (G)	11.95	EM-CET 60"	(E63) or (G70)
	MCB3P 50/ 40	L-G-12	L-2-1 (G)	7.63	EM-CET 38"	(E51) or (G54)
	MCB3P 50/ 50		予備			
	MCB3P 50/ 50		予備			
	MCB3P SPD 225AF クラスT					
	MCB3P 50/ 40	L-E-23	L-2-2 (E)	7.00	EM-FPT 14"	(E39) or (G36)
	MCB2P 50/ 20	L-E-24	発電機補機電源	1.00	EM-FP 5.5"-2C	E 5.5"x2 (E31) or (G28)
	火災信号+停電にてOFF					
		MCB3P 225/175	L-G-13	L-2-2 (G)	31.42	EM-CET100"
MCB3P 225/125		L-G-14	L-2-3 (G)	20.82	EM-CET100"	(E75) or (G70)
MCB3P 225/200		L-G-15	L-2-4 (G)	36.62	EM-CET250"	(G104)
MCB3P 50/ 30		L-G-16	L-2-5 (G)	4.17	EM-CET 14"	(E39) or (G36)
MCB3P 50/ 50		L-G-17	L-3-1 (G)	8.83	EM-CET 38"	(E51) or (G54)
MCB3P 50/ 50		L-G-18	L-3-2 (G)	8.29	EM-CET 14"	(E39) or (G36)
MCB3P 50/ 50		L-G-19	L-3-3 (G)	9.83	EM-CET 38"	(E51) or (G54)
MCB3P 50/ 30		L-G-20	LP-LC (G)	3.68	EM-CET 14"	(E39) or (G36)
MCB3P 50/ 30		L-G-21	L-R (G)	4.00	EM-CET 22"	(E51) or (G42)
MCB3P 50/ 30		L-G-22	L-4-1 (G)	3.35	EM-CET 14"	(E39) or (G36)
MCB3P 50/ 50			予備			
MCB3P 50/ 50			予備			
MCB3P SPD 225AF クラスT						

※ **WH**は積算電力量計（パルス出力）とし中央監視（機械工事）へ出力する。

[illegible]

福岡県建築都市部営繕設備課 福岡市博多区東公園7番7号	承認 approve	設計者 株式会社隈研吾建築都市設計事務所 KENGO KUMA & ASSOCIATES 一級建築士事務所 東京都知事登録 第32752号 管理建築士 一級建築士登録 第319352号 宮原 賢次	工事名称	新福岡県立美術館新築電気設備工事	日付	令和7年7月	図面番号 E-0105
			図面名称	受変電設備 低圧配電盤結線図(2)	【免注図】 縮尺	A1: N.S. A3: N.S.	

Technical drawing of a water meter installation showing top and side views with dimensions and labels.

Top View Dimensions:

- Overall width: 1100
- Overall height: 1200
- Internal width: 1050
- Internal height: 1000
- Side flange width: 20
- Bottom flange width: 20
- Water meter diameter: $\phi 300$

Labels and Notes:

- 給水配管 (給水口) (Supply pipe (supply port))
- 接地端子 (Grounding terminal)
- 接地線 1 V 8 mm以上 (Grounding wire 1 V 8 mm or more)
- 捨コン (Scrap concrete)
- 割栗石 (Crushed stone)
- 水錶埋入 (Water meter embedding)
- E.A (External Access)
- 200 G.L. (200 mm Ground Level)

